

HARO SPORTS FLOOR
C.S.I. GUIDE SPECIFICATION
Rome 20-Portable Floor System

SECTION 09 64 66

WOOD ATHLETIC FLOORING



Model Rome 20

Rome 20 is a portable floor for applications in multi-purpose arenas and ice rinks. It features a patented interlocking system that makes setup and disassembling incredibly fast. Rome 20 needs to be installed on an even sub-floor. The slab should be level according to DIN 18032, part II and DIN 18202:1997-04, figure 3 (compare with "PART 1 – GENERAL" 1.1 Tolerances).

The set-up goes very fast. Every panel incorporates a pair of spring clips and connection discs to secure it to adjacent panels; no pins or screws are required to attach panels together. One 2.14 x 1.07m panel (3' -6 x 7') weighs just 37 kg (82 lbs) accelerating the setup process exceptionally.

Model Rome 25 features a HARO Sports hardwood floorings with 12.6 mm thickness consisting of a premium choice hardwood top layer supported by a top-quality plywood core layer, which sits upon a special 15mm elastic layer consisting of Nike Grind Material. The 3.6mm hardwood top layer receives a factory applied PERMADUR® finish for superior performance and surface protection. Rome 25 fully meets the requirements of German DIN standard 18032-2 and is officially approved by the international Basketball Association (FIBA).

At the moment approx. 50% of the German premier league Basketball teams rely on the quality, safety standards and performance of Rome 25.

The storage boxes are stackable, so you can put up to three boxes on top of one other and save storage space there.

1. Specifications for HARO Sports floor Rome 20

PART 1 - GENERAL

1.01 DESCRIPTION

A. Related work specified under other sections.

B. CONCRETE SUBFLOORS

a) Tolerances: The general contractor shall furnish and install the concrete subfloor depressing the slab sufficiently to accommodate the floor system. The slab should be level within following tolerances according to DIN 18032, part II and DIN 18202:1997-04, figure 3:

- 3mm (1/8") in a radius of 1 meter (3' 3")
- 9mm (3/8") in a radius of 4 meter (13' 1")
- 12mm (1/2") in a radius of 12 meter (39' 4")
- 15mm (5/8") in a radius of 15 meter (49' 2")

For USA: Concrete tolerance 1/8" in radius of 10'

Differing spots shall be ground level, and low spots filled in with approved levelling compound by the general contractor.

b) Waterproof: On or below grade concrete sub-floors are generally acceptable if an effective moisture barrier is installed. Concrete subfloors on or below grade shall be adequately

waterproofed beneath the slab and at the perimeter walls and on earth side of below grade walls by general contractor using suitable type membrane.

- c) Moisture content of sub-floor: Concrete subfloors must not contain more than 2,5% moisture content (appropriate test method). Moisture content of wooden subfloors should be between 6-10%
- d) The subfloor must be clean.

1.02 QUALITY ASSURANCE

A. Floor System Manufacturer Qualifications

- a) Manufacturer shall be an established firm experienced in field and have been in business under the same corporate name for a minimum of ten (10) years.
- b) Manufacturer must meet qualifications of ISO 9001 and 14001.
- c) Manufacturer shall submit a list of projects where the specified flooring has been installed.
- d) Offered sports floors must be FIBA approved.
- e) Sports floor should be under permanent supervision of RAL and be marked with the RAL certificate RAL-GZ 942.

B. Performance Qualifications of Flooring System

- 1. Floor system must exceed the requirements of DIN V 18032-2 Part II, as set out below:

- a) Shock Absorption: shall be minimum of 53%
- b) Ball Return: shall be a minimum of 94%
- c) Deflection: shall be minimum of 2.3mm
- d) Area of Deflection: shall be maximum of 10%
- e) Friction: Range 0.4 - 0.6 per DIN Test Method
- f) Rolling Load: 1500 Newton Load without damage

C. Surface appearance

Appearance, when sections are put together, shall be that of a permanent floor.

The finished flooring shall be installed with no expansion spaces between the individual boards, giving a clean smooth appearance. There should not either be joints or expansion spaces between the lamellas.

1.03 BIDDER MUST PROVIDE EVIDENCE OF ANY DEVIATION from these specifications including detailed drawings and statements itemising, where products deviate from or exceed these specifications. This data shall be provided with bid.

1.04 SUBMITTALS

- a) The Bidder must include the attached Supplemental Pricing Sheet containing detailed costs in an itemised format. Final Purchase Price shall include all freight to Site, Taxes and Duty. It is intended that a final price be submitted.
- b) The Bidder must describe any potential problems which may impact the delivery date.
- c) Manufacturer shall provide written evidence of previous installations of this floor currently in use. Installation shall have taken place within the past ten (10) years. This information shall be submitted with this bid. The Bidder must include a minimum of five (5) references for comparable systems and installation efforts successfully performed by the Bidder within the last 18 months.

- d) Each Bidder is required to provide the following information in the amounts requested. Bidders who fail to provide any of the submittals requested will not be given consideration.

Submit three (3) copies of the Bid Form/Quotation Sheet.

Submit three (3) copies of manufacturer's descriptive literature and manufacturer's fabrication specifications.

Submit three (3) copies of manufacturer's warranty if different from the Vendor's Warranty as required in the Terms and Conditions.

1.05 DELIVERY, STORAGE AND HANDLING

- a) Delivery of Materials

Materials shall not be delivered, stored or installed until all painting and plastering work has been completed, and all overhead mechanical work like lighting, backstops, scoreboards are installed. A room temperature of 18-22 degrees Celsius (64 to 72 degrees Fahrenheit) and a relative humidity of 45-55 % are to be maintained.

- b) Materials shall not be stored at the installation location if the moisture content of the concrete slab differs from paragraph 1.0.1.d. „Moisture content of sub-floor“.

1.06 JOB SITE CONDITIONS

Before installing a floor, inspect the job site thoroughly. Carefully inspect the outside surroundings for improper drainage and predictable or obvious sources of moisture. Be sure that, as a minimum, any concrete subfloor is at least 50-60 days old before installing a wood floor over it and the requirements of paragraph 1.01 B „CONCRETE SUBFLOORS“ are met.

1.07 GUARANTEE

Hamberger Industries GmbH, of Rosenheim, Germany, warrants the materials to be free from manufacturing defects for a period of 5 years.

The Warranty does not cover problems caused in whole or in part by accident, circumstances beyond control, neglect, negligence, ordinary wear and tear, abuse, use for which the material is not designed, faulty construction of the building, settlement of the building walls, failure of other contractors to adhere to specifications, separation of the concrete slab, mechanical failure, excessive dryness, or excessive moisture from humidity, spillage, migration through the slab or walls, or any other source (the excluded conditions).

This warranty is in lieu of all other warranties whether oral, written, expressed, implied or statutory, including but not limiting any warranty of merchantability or fitness for a particular purpose, and of any other obligation on the part of Hamberger Industries GmbH.

Any and all representations, promises, warranties, or statement by the installer or by any other party that differ in any manner from the terms of this written warranty shall be at no force or effect.

Part 2 Products

2.01 MATERIALS

A. HARO Sports Floor Model Rome 25
HARO Resilient underlayment,
HARO Portable floor panels

B. Resilient Underlayment
15 mm (5/8") foam underlayment, density 110kg/m², one-sided laminated coating. Installed staggered over the entire floor.
Panel size shall be 2.24m x 1.51m (7' 4" x 5').

C. Portable floor panels
Fabrication shall consist of 2.14 x 1.07m panels (3'-6" x 7") not weighing more than 37 kg (82 lbs) per full size panel.
Each panel should feature a 12.6 mm hardwood floor consisting of a premium choice hardwood top layer supported by a top-quality plywood core layer. The plywood should be a 7 ply northern birch plywood, using exterior grade (water resistant) glue. All knots and voids will be filled and sanded. The kiln dried 3.6mm hardwood top layer should receive a factory applied UV cured multi layer high-grade mineral varnish (Polyurethane).

Load distribution panels made of plywood components, which are attached to the finished flooring. Side and ends shall be shiplap design. Appearance, when sections are put together, shall be that of a permanent floor. The finished flooring shall be installed with no expansion spaces between the individual boards, giving a clean smooth appearance. There should not either be joints or expansion spaces between the lamellas.

D. Concealed Interlocking System
Interlocking system shall be completely concealed after portable floor is assembled. The end and center-framing members of each panel shall be fitted with a concealed locking system, which interlocks each panel in the floor assembly. Each panel shall interlock with the adjacent panel's sides and ends to form the complete assembly and to prevent horizontal movement of the individual sections. Each panel shall incorporate a pair of spring clips and connection discs to secure it to adjacent panels, no pins or screws shall be used to attach panels together.

E. Ramps
Ramps from the top of the wood floor to the main subfloor shall be furnished with the floor. These ramps shall cover the entire perimeter of the floor. These ramps shall accommodate normal rolling loads. They shall have hidden attachments to the main floor, no screws are allowed. The top of the ramp shall match the wood on the main playing floor.

F. Storage Boxes
Sufficient quantity of storage boxes shall be provided for rapid removal and handling of portable floor to and from the storage area. Boxes shall be made of high-grade plywood to hold the panels and

resilient layer. The boxes shall be able to be moved with a forklift truck. The boxes shall be stackable. Total storage area for a regular basket ball court of 34,24m x 18,19m (112' 10'' x 59' 8'') floor shall not be more than 40m² (430 C.F.).

2. **SANDING AND FINISHING**

Wear coating on finished flooring shall be factory applied with a UV cured multi layer high-grade mineral varnish (Polyurethane). Game lines will be painted on top of the finished flooring with two-component urethane paint which requires no finish over the top. Paint must be HARO game line paint.

Part 3-Execution

3.01 Inspection

- A. Inspect concrete subfloors for proper tolerances and dryness, and report any discrepancies to the general contractor in writing.
- B. All work required to put the concrete subfloors in acceptable condition shall be the responsibility of the general contractor.
- C. Subfloor shall be swept clean by the general contractor prior to flooring installers arriving at the jobsite.

3.02 Installation

- A. Manufacturer will supply one supervisor to help with initial setup of floor

B. Maintenance

1. BASIC CLEANING

Basic cleaning is carried out with our special Wax Remover, using as little water as possible. After basic cleaning the floor plates must be opened in order to allow mop-water which may have seeped in to evaporate.

2. GENERAL CARE

After every basic cleaning, the complete sports floor may be treated with Parquet Gloss.

3. ROUTINE CLEANING

After every day of use, the sports floor should be cleaned by damp mopping. This is necessary for hygienic reasons and to remove dust, hair, light dirt etc. from the surface.

Intermediate care should be carried out once or twice a week, depending on the usage of the hall.

4. HARO BASE BOARDS WITH VENTILATION SLITS

Ventilation slits must be open permanently to provide proper ventilation of the sub-floor. Chewing gum, cigarette ends, paper etc. should be removed from time to time, and dust and dirt should be vacuumed away.

PLEASE NOTE!!:

Wood is a natural product. HARO Hardwood Sports Floor must NOT be flooded with water, since this may cause a swelling of the floor and thus damage the floor. It is therefore essential to be careful when cleaning and maintaining the floor and to economise with water and water-based products. DO NOT USE AN AUTOMATIC SCRUBBING MACHINE, these can be harmful to any wood floor.